

Certificate of Compliance

Certificate Number **050706 - E300802**
Report Reference **E300802, July 4th, 2006**
Issue Date **2006 July 5**

Page 1 of 2



Issued to: **TR-ELECTRONIC GMBH**
EGLISHALDE 6
D-78647 TROSSINGEN GERMANY

This is to certify that representative samples of


Power Circuit and Motor-mounted Apparatus
Enclosed type. Series CE or IE followed by a letter followed by 58
followed by a letter may be followed by a suffix.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **UL 508 Industrial Control Equipment**
CSA C22.2 No. 14 Industrial Control Equipment

Additional Information: See Addendum for Electrical Ratings

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *André Melis*
André Melis, Project Engineer

UL International Germany GmbH

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Germany, you may call +49 (0) 61 02-369-0.

Reviewed by: *Hagen Dahrman*
Hagen Dahrman, Senior Project Engineer

UL International Germany GmbH

Certificate of Compliance

Certificate Number **050706 - E300802**
Report Reference **E300802, July 4th, 2006**
Issue Date **2006 July 5**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL , cUL requirements.

Electrical Ratings:

Power supply: Class 2; 24 Vdc (11..27 Vdc), 3 Watts or less

Signal output variations:

24 Vdc or 5 Vdc, Class 2
Field bus interfaces;
e.g. DeviceNet; CAN bus; SSI, ProfiBus and
others

Max. ambient: 70°C

Issued by:

André Melis, Project Engineer

UL International Germany GmbH

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International Germany GmbH

Reviewed by:

Hagen Dahrman, Senior Project Engineer

UL International Germany GmbH