

Find more detailed information in our web

tr-e.info/01



Accompanying product data sheet for rotary encoders

- _ Basic safety instructions
- _ Purpose
- _ Transport/Storage
- _ Basic assembly instructions

Contact Germany

TR Electronic GmbH
Eglishalde 6
78647 Trossingen
Germany

Phone: +49/7425 228-0
Fax: +49/7425 228-33


info@tr-electronic.de
www.tr-electronic.com

1. General information

1.1 Applicability

This accompanying product data sheet applies exclusively for rotary measuring system series.

1.2 Applicable documents

- _ Operator's system-specific operating instructions
- _ This accompanying product data sheet
- _ assembly instructions
- _ Plug assignment
- _ Interface-specific user manual
- _ Product data sheet
- _ Article number-related dimensional drawing
- _ optional:  -User Manual

1.3 EU Declaration of Conformity

The measuring systems have been developed, designed and manufactured taking account of the applicable European and international standards and directives. A corresponding declaration of conformity can be requested from TR Electronic GmbH. The manufacturer of the products, TR Electronic GmbH in D-78647 Trossingen, has a certified company management system in accordance with ISO 9001.

2. Basic safety instructions


2.1 Definition of symbols and notes


WARNING

means that death or serious injury can occur if the required precautions are not met.

NOTICE

means that damage to property can occur if the required precautions are not met.

 indicates important information or features and application tips for the product used.

 means that appropriate protective measures against ESD according to DIN EN 61340 5-1 Supplement 1 must be applied.

2.2 Operator's obligations before commissioning

As an electronic device, the measuring system is subject to the requirements of the EMC Directive. It is therefore only permitted to start up the measuring system if it has been established that the system/machine into which the measuring system is to be fitted satisfies the provisions of the EU EMC Directive, the harmonized standards, European standards or the corresponding national standards.

2.3 General risks when using the product

The product, herein referred to as **the measuring system**, is manufactured according to state-of-the-art technology and accepted safety rules. **Nevertheless, improper use can pose a danger to life and limb of the user or third parties, or lead to impairment of the measuring system or other property!** Only use the measuring system in perfect technical condition, paying attention to safety and dangers, and in compliance with the **applicable documents!** Faults which could threaten safety should be eliminated without delay!

2.4 Intended use

The measuring system is used to measure linear motion and to condition the measurement data for the subsequent control of industrial control processes.

Proper use also includes

- _ observing all instructions in the applicable documents,
- _ observing the nameplate and any prohibition or instruction symbols on the measuring system,
- _ observing accompanying documents,
- _ operating the measuring system within the limit values specified in the technical data, see product data sheet.

2.5 Improper use


WARNING NOTICE


Danger of death, physical injury and damage to property due to improper use of the measuring system!

- _ Unless stated otherwise, the measuring system does **not constitute a safety component** in accordance with the EU Machinery Directive. In this case a plausibility checks of the measuring system values must be carried out by the downstream control.
- _ It is mandatory for the operator to integrate the measuring system into his own safety concept.
- _ The following use is prohibited in particular:
 - in environments where there is an explosive atmosphere in accordance with the ATEX Directive
 - for medical purposes in accordance with the Medical Devices Directive
 - as a strain relief for connections
- _ climbing aid
- _ support for tensioning chains, etc.

2.6 Use in explosive atmospheres


For use in explosive atmospheres the standard measuring system is installed in a suitable explosion-proof enclosure, depending on the requirements.

The products are identified on the type plate with an additional  -marking.

The "Intended use" and all information on safe use of the ATEX-compliant measuring system in explosive atmospheres are contained in the  -user manual, which is enclosed with the delivery.

The standard measuring system installed in the explosion-proof enclosure can therefore be used in explosive atmospheres.

The original characteristics of the measuring system are changed by installation in the explosion-proof enclosure and the explosion protection requirements.

On the basis of the specifications in the  -user manual, it is necessary to check that the characteristics defined there satisfy the application-specific requirements.

Additional measures or requirements are necessary for safe use. These must be determined before initial commissioning and implemented accordingly.

2.7 Use in safety-related applications

Measuring systems for use in safety-related applications are identified by an additional safety marking on the type plate:

SIL..., PL..., KAT...

The "Intended use" and all information for safe use of the safety measuring system in safety-related applications can be found in the manual. Use in safety-related applications results in additional requirements when installing the measuring system (fault exclusion).

These additional installation requirements are an integral part of the safety manual and must be taken into account during installation. In general, the requirements and acceptance conditions for the complete system must be taken into account for mounting.

- _ The operating instructions must be observed.
- _ Functional safety parameters are an integral part of the operating instructions
- _ Coupling breakage is not detected

2.8 Warranty and liability

The General Terms and Conditions ("Allgemeine Geschäftsbedingungen") of TR Electronic GmbH always apply. These are available to the operator with the Order Confirmation or when the contract is concluded at the latest. Warranty and liability claims in the case of personal injury or damage to property are excluded if they result from one or more of the following causes:

- _ Improper use of the measuring system
- _ Improper assembly, installation, start-up and programming of the measuring system.
- _ Incorrectly undertaken work on the measuring system by unqualified personnel.
- _ Operation of the measuring system with technical defects.
- _ Mechanical or electrical modifications to the measuring systems undertaken autonomously.
- _ Unauthorized repairs.
- _ Third party interference and acts of God.

2.9 Organizational measures

The applicable documents must be kept ready to hand at all times at the place of use of the measuring system.


In addition to the applicable documents, generally valid and other binding regulations on accident prevention and environmental protection must be observed and communicated.

The respective applicable national, local and system specific provisions and requirements must be observed and communicated.

The operator is obliged to inform personnel of special operating features and requirements.

Prior to commencing work, personnel working with the measuring system must have read and understood this accompanying product data sheet, especially the chapter "Basic safety instructions".

The type plate and any prohibition or instruction symbols applied on the measuring system must always be maintained in a legible state.

Do not undertake any mechanical or electrical modifications to the measuring system, except for those expressly described in the applicable documentation. 

Repairs may only be undertaken by the manufacturer or a center or person authorized by the manufacturer.

2.10 Personnel selection and qualification; basic obligations

All work on the measuring system must only be carried out by **qualified personnel**. Qualified personnel are persons, who, through their training, experience and instruction, as well as their knowledge of the relevant standards, provisions, accident prevention regulations and operating conditions, have been authorized by the persons responsible for the system to carry out the required work and are able to recognize and avoid potential hazards.





Clearly assign responsibilities for assembly, installation, commissioning and operation. It is essential to provide supervision for trainee personnel!


2.11 Safety information


WARNING

NOTICE

Destruction, damage or malfunction of the measuring system and risk of physical injury!

- _ Only carry out wiring work or connect and disconnect electrical connections with the system de-energized. 
- _ Connection of equipotential bonding
- _ Do not undertake any welding work if the measuring system is already wired or switched on.
- _ Make sure that the installation environment is protected from aggressive media (acids etc.)
- _ SELV/PELV supply 
- _ Avoid shocks (e.g. hammer blows) to the shaft during installation. 
- _ Opening the measuring system is forbidden. 
- _ Only operate the system within the specified ambient conditions.
- _ During storage and operation of the measuring system, unused connection plugs must either be provided with a mating plug or a protective cap. The appropriate IP protection class must be selected to meet the relevant requirements.

 **The measuring system contains electrostatically sensitive components and assemblies, which can be destroyed if incorrectly handled.**
- Touching the measuring system connection contacts with the fingers must be avoided, and the relevant ESD protective measures must be applied.

 **Disposal**
Electronic waste is classified as hazardous waste. The local regulations must be observed for disposal.

3. Transport/Storage

Do not drop the device or subject it to heavy impacts!

Use only the original packaging.

- _ Inappropriate packaging material may cause damage to the device in transit.
- _ Storage temperature: see product data sheet, store in a dry place
- _ Cover unused connections

4. Maintenance

The measuring systems are basically maintenance-free. The bearings wear out depending on the applied bearing loads or operating points. Information on the bearing life time can be found in the product data sheets.


5. Basic installation instructions

The installation instructions valid for the respective series must be observed. As the installation situation is application-dependent, the following notes are not exhaustive.

 Incorrect execution will result in loss of functionality.

5.1 Solid shaft version

- _ A suitable coupling must be used for the application.
- _ The coupling manufacturer's information and installation requirements must be observed.
- _ The coupling must be suitable for the specified speed and the potential axial offset.
- _ The coupling and the measuring system should not be axially loaded.
- _ The clamping screws must be tightened with the torque defined by the coupling manufacturer.
- _ The coupling screws must be secured against unintentional loosening.
- _ The coupling must be designed accordingly.




Components Solid shaft

- | | |
|---|--|
| 1) Measuring system | 3) Coupling, optionally with groove |
| 2) Solid shaft (optionally with parallel key) | 4) customer shaft (optionally with parallel key) |

5.2 Blind shaft/hollow shaft version

The measuring system must be installed on a grease-free shaft.

- _ The clamping of the measuring system should not be axially loaded.
- _ Provide torque support
- _ The screw of the clamping ring must be tightened with 2 Nm using a torque wrench.
- _ The screw of the clamping ring must be secured against unintentional loosening.




Components Blind shaft/hollow shaft:

- | | |
|--|--|
| 1) Measuring system | 3) Blind-/hollow shaft (optionally with groove) |
| 2) clamping ring, optionally with groove | 4) customer shaft (optionally with parallel key) |

6. UL / CSA approval

Measuring systems with this approval are identified by the UL symbol on the type plate:




These measuring systems comply with the following UL/cUL requirements:

- _ US Standard UL508, Industrial Control Equipment
- _ Canadian Standard CSA C22.2 No. 107.1-01, General Use Power Supplies

It is therefore only permitted to start up these measuring systems if it has been established that the system/machine into which the measuring system is to be fitted satisfies the following requirements:

- _ NFPA 79 Standard, "Electrical Standard for Industrial Machinery"
- _ Class 2 voltage source, according to NEC requirements
- _ Supply voltage (device-specific values, see type plate) 24 V DC (4 ... 30 V DC), ≤ 6 watts or 5 V DC (4.75 ... 5.25 V DC), ≤ 6 watts
- _ Ambient temperature ≤ 75°C, type 1

 UL-compliant cables are available from the manufacturer

7. Explanation of type plate

Operation of the measuring system is only permitted with a legible type plate!

The following information can be taken from the type plate (the arrangement, content and labeling may differ depending on the measuring system and type plate version):

- _ **Device version**
- _ **Article number**
- _ **SN** (serial number for identification of a specific measuring system of a device type)
- _ **CE / UKCA / UL / Atex (EX)/...** (reference to certifications/conformities)
- _ **Steps/Revs** (resolution, factory setting)
- _ **Interface** (interface properties)
- _ **+US** (voltage: specified supply voltage)
- _ **Power** (power consumption)
- _ **max** (maximum speed)
- _ **Pinout** (pin assignment no.)
- _ **DOM** (production date: week/year)
- _ **MAC** (Mac address)

Example type plate

Illustration similar, other arrangement and labelling depending on the measuring system and type plate design.

 TR Electronic GmbH Eglishalde 6 D-78647 Trossingen	Steps	8:192
	Revs	4:096
+US	Profinet IO + INK	
Power	10-30V Class 2	
max	> 4 Watt	
Pinout	3000 1/min.	
DOM	TR-ECE-TI-DGB-0000	
MAC	DATE ...	
SN: SNXX	MA-X0:00:00:00:00	
CE	Gas  CE II 2G Ex db IIC T6	
UKCA	Staub  CE II 2D Ex tb IIC T80°C	
UL		
Ex		
Do not disconnect under voltage!		

6. Important information on the "TRWinProg" programming software

Some TR measuring systems are programmed with the "TRWinProg" programming software. Detailed information can be found in the description of characteristics in the delivery note. If applicable, the measuring system is identified with this symbol:



CDs can be ordered from TR Sales (article no.: 490-00416) free of charge.

The software and updates are also available on the Internet under www.tr-electronic.de.

Measuring systems with the EPROG programming interface **CANNOT** be programmed with this software.